

RELIEF POWER CONTROL PANEL

NO 11. GODOWN, NARODA GIDC ROAD, BEHIND NMTG INDIA, PHASE 2,
NAVA NARODA, AHMEDABAD, GUJARAT - 382330.
Website : www.reliefpowercontrolpanel.com

PANEL NAME :- 250AMAIN +125A DG MCCB LT POWER DISTRIBUTION PANEL

SR. NO.	BOQ DESCRIPTION	MAKE	QTY
A	INCOMING-MAIN		
1	250A 4P 36kA MCCB	SCHNEIDER	1
2	R,Y,B INDICATION LAMP	ESBEE	3
3	MULTIFUNCTION METER	SELEC	1
B	OUTGOING	MAKE	FEEDER QTY
1	160A 4P 25kA MCCB	SCHNEIDER	2
2	125A 4P 25kA MCCB	SCHNEIDER	1
3	100A 4P 25kA MCB	SCHNEIDER	1
4	63A 4P 25kA MCCB	SCHNEIDER	2
5	32A 4P 10kA MCB	SCHNEIDER	4
A-1	INCOMING-DG		
1	125A 4P 25kA MCCB	SCHNEIDER	1
2	R,Y,B INDICATION LAMP	ESBEE	3
3	MULTIFUNCTION METER	SELEC	1
B-1	OUTGOING-DG	MAKE	FEEDER QTY
1	63A 4P 25kA MCCB	SCHNEIDER	2
2	32A 4P 10kA MCB	SCHNEIDER	4
C	FABRICATION & BUSBAR DETAILS	MAKE	QTY
1	PANEL SIZE : AS PER REQRIMENT WE SHARE FABRICATION : 16 SWG CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FLOOR MOUNTING, FIXED TYPE, SINGLE FRONT, COMPARTMENTLISED, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)		1
2	POWER WIRING: FLEXIBLE COPPER WIRE	LAPP/POLYCAB/RR/KEI	LOT
3	CONTROL WIRING: FLEXIBLE COPPER WIRE	LAPP/POLYCAB/RR/KEI	LOT
4	BUSBAR: PH: 1x20x10, N: 1X20X10, E: 1X20X6 Current Density: 0.8 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	ISO STD MAKE	1